

List of GETCO EHV substations for RE integration : September-2021

| Sr. No. | Name of District | Name of Substation | Available Voltage Class | Tentative Feasible RE Capacity (MW) |
|---|------------------|--------------------------|-------------------------|---|
| Note: | | | | |
| (1) This list is indicative only and does not stipulate available evacuation capacity at these substations. | | | | |
| (2) Based on application for connectivity by applicant, feasibility of point of interconnection and strengthening requirement, if any, shall be assessed. | | | | |
| (3) Maximum RE power integration at each voltage class may be considered as; (i) upto 130 MW at 132 KV level, (ii) upto 500 MW at 220 KV level & (iii) > 500 MW for 400 KV level. This capacity includes RE integration at downstream level also. | | | | |
| (4) RE power integration at EHV level shall be finalized after detailed system study. | | | | |
| (5) The availability of required feeder bays at each GETCO substation is to be checked separately after receipt of an application. | | | | |
| (6) Kindly note that space is available inside switchyard, but there may be issues of line corridor, ROW, building control line etc. at some locations. | | | | |
| 1 | Gandhinagar | 400KV Soja | 220 KV | 132 KV - 80 to 130 MW 220 KV - 200 to 500 MW Total feasible capacity of the cluster is around 1000-1200 MW. |
| 2 | Aravalli | 220KV Dhansura | 220 KV | |
| 3 | Aravalli | 220KV Faredi (Modasa) | 220 KV | |
| 4 | Sabarkantha | 220KV Bhutiya (Mathasur) | 220 KV | |
| 5 | Gandhinagar | 220KV Jamla | 220 KV | |
| 6 | Mehsana | 220KV Mitha (Jotana) | 220 KV | |
| 7 | Sabarkantha | 220KV Agiyol | 132 KV | |
| 8 | Mehsana | 220KV Mehsana | 132 KV | |
| 9 | Patan | 132KV Sidhpur | 132 KV | |
| 10 | Patan | 132KV Patan | 132 KV | |
| 11 | Mehsana | 132KV Visnagar | 132 KV | |
| 12 | Banaskantha | 400KV Kansari (Zerda) | 400 KV | 220 KV - 100 to 500 MW Total feasible capacity of the cluster is around 1000-1200 MW. |
| 13 | Patan | 400 KV Veloda | 400 KV / 220 KV | |
| 14 | Patan | 220KV Sankhari | 220 KV | |
| 15 | Banaskantha | 220KV Palanpur | 220 KV | |
| 16 | Banaskantha | 220KV Agathala | 220 KV | 132 KV - 80 to 130 MW 220 KV - 200 to 500 MW Total feasible capacity of the cluster is around 1000-1200 MW. |
| 17 | Mahisagar | 220KV Savdasna Muvada | 220 KV | |
| 18 | Panchmahal | 220KV Godhra | 132 KV | |
| 19 | Dahod | 220KV Rupakheda (Zalod) | 220 KV / 132 KV | |
| 20 | Chotaudaipur | 132KV Zoz | 132 KV | |
| 21 | Dahod | 132KV Dahod | 132 KV | 132 KV - 80 to 130 MW 220 KV - 200 to 500 MW Total feasible capacity of the cluster is around 1000-1200 MW. |
| 22 | Vadodara | 400KV Asoj | 220 KV | |
| 23 | Vadodara | 220KV Gotri | 132 KV | |
| 24 | Chotaudaipur | 220KV Kawant | 220 KV | |
| 25 | Chotaudaipur | 132KV Vasedi | 132 KV | |
| 26 | Vadodara | 132KV Javahar nagar | 132 KV | |
| 27 | Vadodara | 132KV Manjusar | 132 KV | |
| 28 | Anand | 132KV Ode | 132 KV | 200-500 MW |
| 29 | Gandhinagar | 220KV Khanpur | 220 KV | |
| 30 | Valsad | 220KV Bhilad | 220 KV | 200-500 MW |
| 31 | Mehsana | 400KV Vadavi | 400 KV / 220 KV | 200-500 MW |
| 32 | Rajkot | 400KV Hadala | 400 KV | 200-500 MW |
| 33 | Anand | 400KV Kasor | 220 KV | 200-500 MW |
| 34 | Ahmedabad | 132KV Narol | 132 KV | 80-130 MW |
| 35 | Ahmedabad | 400KV Chharodi (Sanand) | 400 KV / 220 KV | 200-500 MW |
| 36 | Gir Somnath | 132KV Talala | 132 KV | 70-100 MW |

List of GETCO EHV substations for RE integration : September-2021

| Sr. No. | Name of District | Name of Substation | Available Voltage Class | Tentative Feasible RE Capacity (MW) |
|--|------------------|---|---|---|
| <p>Note:</p> <p>(1) This list is indicative only and does not stipulate available evacuation capacity at these substations.</p> <p>(2) Based on application for connectivity by applicant, feasibility of point of interconnection and strengthening requirement, if any, shall be assessed.</p> <p>(3) Maximum RE power integration at each voltage class may be considered as; (i) upto 130 MW at 132 KV level, (ii) upto 500 MW at 220 KV level & (iii) > 500 MW for 400 KV level. This capacity includes RE integration at downstream level also.</p> <p>(4) RE power integration at EHV level shall be finalized after detailed system study.</p> <p>(5) The availability of required feeder bays at each GETCO substation is to be checked separately after receipt of an application.</p> <p>(6) Kindly note that space is available inside switchyard, but there may be issues of line corridor, ROW, building control line etc. at some locations.</p> | | | | |
| 37 | Surat | 400KV Kosamba | 400 KV / 220 KV | 132 KV - 80 to 130 MW 220 KV - 200 to 500 MW Total feasible capacity of the cluster is around 1500-2000 MW. |
| 38 | Surat | 220KV Kim | 220 KV | |
| 39 | Surat | 220KV Vav | 220 KV | |
| 40 | Surat | 220KV Ichchhapor | 220 KV | |
| 41 | Surat | 220KV Popda | 220 KV / 132 KV | |
| 42 | Bharuch | 220KV Haldarva | 220 KV / 132 KV | |
| 43 | Bharuch | 220KV Wagra | 220 KV | |
| 44 | Bharuch | 220KV Suva (Rahiyad) | 220 KV | |
| 45 | Bharuch | 220KV Achhalia | 220 KV | |
| 46 | Tapi | 220KV Virpore (Vyara) | 220 KV | |
| 47 | Bharuch | 220KV Zaghadia | 220 KV | |
| 48 | Bharuch | 132KV Ankleshwar | 132 KV | |
| 49 | Bharuch | 132KV Bharuch | 132 KV | |
| 50 | Narmada | 132KV Tilakwada | 132 KV | |
| 51 | Bharuch | 132KV Valiya | 132 KV | |
| 52 | Surat | 132KV Bhestan | 132 KV | |
| 53 | Vadodara | 220KV Karjan | 132 KV | |
| 54 | Kutch | -400 KV Adani / GSBPL switchyard, nearby 400 KV Varsana (GETCO) substation - Adani / GSBPL to provide space at their switchyard free of cost & connectivity equipments will be provided by upcoming developer. - Cost of 400 KV line from Adani switchyard to Varsana (GETCO S/S) to be shared by developer with Adani / GSBPL | 250-300 MW - 400 KV direct line OR - 220 KV / 132 KV line along with associated switchyard at Adani switchyard space & additional 400/220 KV OR 400/132 KV ICT at Adani switchyard | |
| 55 | Vadodara | - 220 KV Waghodia direct line OR -220 KV NTPC switchyard, nearby 220 KV Waghodia (GETCO) substation - NTPC to provide space at their switchyard free of cost & connectivity equipments will be provided by upcoming developer. - Cost of 220 KV line from NTPC switchyard to Waghodia (GETCO S/S) to be shared by developer with NTPC. | 100-150 MW | |
| 56 | Ahmedabad | - 220 KV Bechraji direct line OR -220 KV Torrent switchyard, nearby 220 KV Bechraji (GETCO) substation - Torrent to provide space at their switchyard free of cost & connectivity equipments will be provided by upcoming developer. - Cost of 220 KV line from Torrent switchyard to Bechraji (GETCO S/S) to be shared by developer with Torrent. | 100-150 MW | |